# **TRIDONIC**





# PC TCL PRO, 18 - 55 W

T8 and TC-L compact fluorescent lamps (CFL)

## **Product description**

- Average life = 50,000 hours (at max ta.
   with a failure rate ≤ 0.2 % per 1,000 hours)
- Large temperature range (for values see table)
- Safety shutdown at end of life
- Automatic start after replacement of defective lamps
- For emergency lighting systems as per EN 50172
- · Constant luminous flux irrespective of fluctuations in mains voltage
- For luminaires of protection class 1 and protection class 2
- For luminaires with F or M and MM as per EN 60598,
   VDE 0710 and VDE 0711
- Insulation Displacement Connection (IDC) terminal for rapid automatic or manual wiring
- Temperature protection as per EN 61347-2-3 C5e

#### Technical data


AC voltage range	198 – 264 V
DC voltage range	176 - 280 V (Lamp start ≥ 198 V DC)
Overvoltage protection	320 V AC, 1 h
Defined warm start	≤ 1.5 s
Operating frequency	≥ 40 kHz
Type of protection	IP20



# Standards, page 2

Wiring diagrams and installation examples, page 4





## Ordering data

Туре	Article number			
For luminaires with 1 lamp				
PC 1/18/24 TCL PR0	22176068			
PC 1/36 TCL PR0	22176141			
PC 1/40 TCL PR0	22176142			
PC 1/55 TCL PR0	22176169			
For luminaires with 2 lamps				
PC 2/18/24 TCL PR0	22176069			
PC 2/36 TCL PR0	22176170			
PC 2/40 TCL PR0	22176143			
PC 2/55 TCL PR0	22176233			

Packaging 234 mm casing: 10 pieces/carton, 630 pieces/pallet Packaging 360 mm casing: 10 pieces/carton, 420 pieces/pallet

# Specific technical data

Lamp	Lamp	Туре	Length L	Hole	Weight	Lamp	Circuit	EEI	Current	at 50 Hz	λ at 5	50 Hz	tc point	Ambient
wattage	type			spacing D		wattage	power		220 V	240 V	220 V	240 V		temperature ta
For lumir	naires w	vith 1 lamp												
1 x 18 W	TC-L	PC 1/18/24 TCL PRO	234 mm	220 mm	0.28 kg	16 W	18.5 W	АЗ	0.09 A	0.08 A	0.96	0.94	75 °C	-25 60 °C
1 x 24 W	TC-L	PC 1/18/24 TCL PRO	234 mm	220 mm	0.28 kg	22 W	25.0 W	АЗ	0.12 A	0.11 A	0.98	0.96	75 °C	-25 60 °C
1 x 38 W	T8	PC 1/36 TCL PRO	234 mm	220 mm	0.18 kg	32 W	34.2 W	A2	0.16 A	0.14 A	0.99	0.98	70 °C	-25 60 °C
1 x 36 W	TC-L	PC 1/36 TCL PRO	234 mm	220 mm	0.18 kg	32 W	33.8 W	A2	0.16 A	0.14 A	0.99	0.98	70 °C	-25 60 °C
1 x 40 W	TC-L	PC 1/40 TCL PRO	234 mm	220 mm	0.18 kg	40 W	44.1 W	A2	0.20 A	0.19 A	0.99	0.98	70 °C	-25 60 °C
1 x 55 W	TC-L	PC 1/55 TCL PRO	234 mm	220 mm	0.20 kg	55 W	61.1 W	A2	0.28 A	0.26 A	0.98	0.98	75 °C	-25 55 °C
For lumin	naires w	vith 2 lamps												
2 x 18 W	TC-L	PC 2/18/24 TCL PRO	234 mm	220 mm	0.28 kg	32 W	36.0 W	A2	0.17 A	0.16 A	0.98	0.96	75 °C	-25 60 °C
2 x 24 W	TC-L	PC 2/18/24 TCL PRO	234 mm	220 mm	0.28 kg	44 W	49.0 W	A2	0.22 A	0.21 A	0.99	0.97	75 °C	-25 60 °C
2 x 38 W	T8	PC 2/36 TCL PRO	234 mm	220 mm	0.22 kg	64 W	72.6 W	A2	0.34 A	0.31 A	0.98	0.98	75 °C	-25 50 °C
2 x 36 W	TC-L	PC 2/36 TCL PRO	234 mm	220 mm	0.22 kg	64 W	72.8 W	A2	0.34 A	0.31 A	0.98	0.98	75 °C	-25 50 °C
2 x 40 W	TC-L	PC 2/40 TCL PRO	234 mm	220 mm	0.22 kg	80 W	89.6 W	A2	0.42 A	0.38 A	0.99	0.98	75 °C	-25 55 °C
2 x 55 W	TC-L	PC 2/55 TCL PRO	360 mm	350 mm	0.30 kg	110 W	121.1 W	A2	0.56 A	0.52 A	0.99	0.99	70 °C	-25 50 °C

## Standards

EN 55015

EN 61347-2-4

EN 61347-2-3

EN 60929

EN 61000-3-2

EN 61547

according to EN 50172

IEC 68-2-64 Fh

IEC 68-2-29 Eb

IEC 68-2-30

## Lamp starting characteristics

Warm start

Starting time < 1.5 secs with AC and DC operation Cathode heating will be reduced after preheat time

#### AC operation

Mains voltage:  $220-240\ V\ 50/60\ Hz$   $198-264\ V\ 50/60\ Hz\ including\ safety$  tolerance ( $\pm10\ \%$ )  $202-254\ V\ 50/60\ Hz\ including\ performance$  tolerance ( $+6\ \%\ /\ -8\ \%$ )

# DC operation

220–240 V 0 Hz 198–280 V 0 Hz certain lamp start 176–280 V 0 Hz operating range Light output level in DC operation: 100 %

#### **Emergency lighting**

Use in emergency lighting installations according to EN 50172 or for emergency luminaires according to EN 61347-2-3 appendix J.

Instant start after mains interruption  $< 0.5 \ s$ 

# Intelligent Voltage Guard

Intelligent Voltage Guard is the name of the new electronic monitor from Tridonic. This innovative feature of the PC PRO family of control gear from Tridonic immediately shows if the mains voltage rises above or falls below certain thresholds. Measures can then be taken quickly to prevent damage to the control gear.

- If the mains voltage rises above approx. 306 V (voltage depends on the ballast type), the lamp starts flashing on and off.
- This signal "demands" disconnection of the power supply to the lighting system.
- If the mains voltage falls below 150 V the control gear automatically disconnects the lamp circuit to protect the control gear from being irreparably damaged.

#### **Smart Heating**

Innovative heating circuit. Reduced filament heating after lamp ignition.

#### Mains current in DC operation

			Mains current at	Mains current at
Туре	Lamp type	Wattage	$U_{\text{n}}=220V_{\text{DC}}$	$U_{\text{n}}=240V_{\text{DC}}$
PC 1/18/24 TCL PRO	TC-L	1x18W	80 mA	75 mA
PC 1/18/24 TCL PRO	TC-L	1x24W	114 mA	105 mA
PC 1/36 TCL PRO	T8	1x38W	157 mA	143 mA
PC 1/36 TCL PRO	TC-L	1x36W	155 mA	142 mA
PC 1/40 TCL PRO	TC-L	1x40W	202 mA	185 mA
PC 1/55 TCL PRO	TC-L	1x40W	280 mA	256 mA
PC 2/18/24 TCL PR0	TC-L	2x18W	160 mA	147 mA
PC 2/18/24 TCL PR0	TC-L	2x24W	231 mA	214 mA
PC 2/36 TCL PRO	T8	2x38W	333 mA	304 mA
PC 2/36 TCL PRO	TC-L	2x36 W	333 mA	305 mA
PC 2/40 TCL PRO	TC-L	2x40 W	412 mA	377 mA
PC 2/55 TCL PRO	TC-L	2x55 W	556 mA	507 mA

#### Harmonic distortion in the mains supply

			THD
Тур	Lamp type	Wattage	at 230 V / 50 Hz
PC 1/18/24 TCL PRO	TC-L	1x18W	< 10 %
PC 1/18/24 TCL PRO	TC-L	1x24W	< 10 %
PC 1/36 TCL PRO	T8	1x38W	< 10 %
PC 1/36 TCL PRO	TC-L	1x36 W	< 10 %
PC 1/40 TCL PRO	TC-L	1x40 W	< 10 %
PC 1/55 TCL PRO	TC-L	1x40 W	< 10 %
PC 2/18/24 TCL PR0	TC-L	2x18W	< 10 %
PC 2/18/24 TCL PR0	TC-L	2x24W	< 10 %
PC 2/36 TCL PRO	T8	2x38 W	< 10 %
PC 2/36 TCL PRO	TC-L	2x36 W	< 10 %
PC 2/40 TCL PRO	TC-L	2x40 W	< 10 %
PC 2/55 TCL PRO	TC-L	2x55 W	< 10 %

#### Working voltage

Туре	Lamp type	Wattage	$U_{\text{out}}$
PC 1/18/24 TCL PRO	TC-L	1x18W	250 V
PC 1/18/24 TCL PRO	TC-L	1x24W	250 V
PC 1/36 TCL PRO	T8	1x38 W	250 V
PC 1/36 TCL PRO	TC-L	1x36 W	250 V
PC 1/40 TCL PRO	TC-L	1x40 W	250 V
PC 1/55 TCL PRO	TC-L	1x40 W	250 V
PC 2/18/24 TCL PRO	TC-L	2x18W	250 V
PC 2/18/24 TCL PRO	TC-L	2x24W	250 V
PC 2/36 TCL PRO	T8	2x38 W	250 V
PC 2/36 TCL PRO	TC-L	2x36 W	250 V
PC 2/40 TCL PRO	TC-L	2x40 W	250 V
PC 2/55 TCL PRO	TC-L	2x55 W	250 V
·			

# Ballast lumen factor (EN 60929 8.1)

			AC/DC-BLF
Туре	Lamp type	Wattage	bei U = 198-254 V, 25 °C
PC 1/18/24 TCL PR0	TC-L	1x18W	0.98
PC 1/18/24 TCL PRO	TC-L	1x24W	1.00
PC 1/36 TCL PRO	T8	1x38 W	1.00
PC 1/36 TCL PRO	TC-L	1x36 W	1.00
PC 1/40 TCL PRO	TC-L	1x40 W	1.00
PC 1/55 TCL PRO	TC-L	1x40 W	1.00
PC 2/18/24 TCL PR0	TC-L	2x18W	0.99
PC 2/18/24 TCL PR0	TC-L	2x24 W	1.00
PC 2/36 TCL PRO	T8	2x38 W	1.00
PC 2/36 TCL PRO	TC-L	2x36 W	1.00
PC 2/40 TCL PRO	TC-L	2x40 W	1.00
PC 2/55 TCL PRO	TC-L	2x55 W	1.00

#### PC PRO with xitec processor


Is the very latest in lighting management design technology. The lamp friendly warm start is delivering maximum lamp life and enables high switching frequency applications. Smallest power loss and new freedom in the lamp design thanks to convincing thermal management.

#### **Energy class CELMA**


PC TCL PRO ignition technology (smart heating) optimises lamp start and ensures no energy is wasted. After the lamp has struck the filament heating is reduced automatically to a defined minimum value. This reduction in filament heating, saves energy, yet maintains the proper operating conditions for the lamp. The lamp is always operated within specification.

ballast life duration.


## **Ambient Temperature**



PC 1/36 TCL PRO PC 2/36 TCL PRO PC 1/40 TCL PRO PC 1/55 TCL PRO PC 2/40 TCL PRO



PC 2/55 TCL PRO



PC 1/18/24 TCL PRO PC 2/18/24 TCL PRO ELCAP) measured.
Detailed information on request.

PC TCL PRO is designed for an average service life of 50,000 hours under reference conditions and

The nominal ta and to point are related to the

The relation of tc to ta temperature depends also on the luminaire design. If the measured tc temperature is approx. 5K below tc max., ta temperature should

be checked and eventually critical components (e.g.

of 50,000 hours under reference conditions and with a failure probability of less than 10 %. This corresponds to an average failure rate of 0.2 % for every 1,000 hours of operation.

Humidity: 5 % up to max. 85 %,

not condensed

(max. 56 days/year at 85 %)

Storage temperature: -40 °C up to max. +80 °C

The devices have to be within the specified temperature range (ta) before they can be operated.

## Maximum loading of automatic circuit breakers

Automatic circuit	C10	C13	C16	C20	B10	B13	B16	B20
Installation Ø	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	2.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>	$2.5\mathrm{mm}^2$
PC 1/18/24 TCL PRO	30	40	48	60	15	20	24	30
PC 1/36 TCL PRO	34	48	54	68	17	24	27	34
PC 1/40 TCL PRO	32	46	52	62	16	23	26	31
PC 1/55 TCL PRO	28	38	50	60	14	19	25	30
PC 1/18/24 TCL PRO	24	32	38	46	12	16	19	23
PC 1/36 TCL PRO	24	34	44	50	12	17	22	25
PC 1/40 TCL PRO	16	24	28	32	8	12	14	16
PC 1/55 TCL PRO	8	14	18	20	4	7	9	10

#### Wiring advice

The lead length is dependant on the capacitance of the cable.

For safety reasons, the PC TCL PRO must only be earthed in the case of a safety class 1 luminaire. Earthing is not required for the device to operate. Connection to earth reduces radio interference.

Ballast	Terminal	Maximum capacitance allowed					
Туре	Cold	Hot	Kalt	Heiß			
PC 1xx TCL PRO	11, 12	9, 10	200 pF	100 pF			
PC 2xx TCL PRO	11, 12, 13, 14	9, 10	200 pF	100 pF			

To avoid the damage of the control gear, the wiring must be protected against short circuits to earth (sharp edged metal parts, metal cable clips, louver, etc.).

With standard solid wire 0.5/0.75 mm² the capacitance of the lead is approx. 30–80 pF/m. This value is influenced by the way the wiring is made. In borderline cases the capacitance must be measured inside the luminaire.

Keep lamp wires short. Lamp connection with twin ballast should be made with symmetrical wiring. Hot leads (9.10) and cold leads (11.12.13.14) should be separated as much as possible.


#### Installation instructions

#### **IDC** interface

• solid wire with a cross section of 0.5 mm<sup>2</sup> according to the specification from WAGO

#### Horizontal interface


- solid wire with a cross section of 0.5-1.5 mm<sup>2</sup> according to the specification from WAGO
- strip 7.5-8.5 mm of insulation from the cables to ensure perfect operation of the push terminals




# T8 lamp-information



# TC-L lamp-information





leads 9, 10 max. 1.0 m (< 100 pF) leads 11, 12 max. 2.0 m (< 200 pF)

Protection class I - luminaires: earth of ballast housing required (according to IEC 598)

Protection class II - luminaires: no earth required

## PC 1x18-55 W TCL PR0

#### RFI

Tridonic ballasts are RFI protected in accordance with EN 55015. To operate the luminaire correctly and and to minimise RFI we recommend the following instructions:

- Connection to the lamps of the "hot leads" must be kept as short as possible
- Mains leads should be kept apart from lamp leads (ideally 5-10 cm distance)
- . Do not run mains leads adjacent to the electronic ballast
- Twist the lamp leads
- Keep the distance of lamp leads from the metal work as large as possible
- · Ballast must be earthed, either over the terminal or over the mounting screw of the ballast
- Mains wiring to be twisted when through wiring
- . Keep the mains leads inside the luminaire as short as possible

#### **Defective lamp**

If a lamp is defective, the ballast switches off and goes into standby. There is an automatic restart once the lamp has been changed.

#### Isolation and electric strength testing of luminaires

Electronic devices can be damaged by high voltage. This has to be considered during the routine testing of the luminaires in production.

According to IEC 60598-1 Annex Q (informative only!) or ENEC 303-Annex A, each luminaire should be submitted to an isolation test with 500 V pc for 1 second. This test voltage should be connected between the interconnected phase and neutral terminals and the earth terminal.

The isolation resistance must be at least  $2M\Omega$ .


As an alternative, IEC 60598-1 Annex Q describes a test of the electrical strength with 1500 V  $_{\mbox{\scriptsize AC}}$  (or 1.414 x 1500 V  $_{\mbox{\scriptsize DC}}$  ). To avoid damage to the electronic devices this test must not be conducted.

#### Additional information

Additional technical information at www.tridonic.com → Technical Data

Guarantee conditions at www.tridonic.com → Services

No warranty if device was opened.



leads 9, 10 max. 1.0 m (< 100 pF) leads 11, 12, 13, 14 max. 2.0 m (< 200 pF)

Protection class I - luminaires: earth of ballast housing required (according to IEC 598) Protection class II - luminaires: no earth required

## PC 2x18-55 W TCL PR0